

RFAI Addendum #1 RFP #20-01
Phase 4 Drainage Improvements

1. Sod type clarifications for various project areas:

Project area 1 - Frontage Rd. - Bahia Sod

Project area 2 - Biltmore Dr. - Bahia Sod

Project area 3 - Mantua Ave. - Bahia Sod

Project area 4 - Tagus St. - Bahia Sod

Project area 5 - Cremona Dr. - Bahia Sod

Project area 6 - Sunrise Dr. - St. Augustine Sod

2. Sediment control measure locations have been added to the plans.

3. The Cremona Dr. side lot culvert may utilize 15" RCP in place of the 12" x 18" ERCP. Additional fill for cover may be required or sumping of the pipe an additional 3" to compensate will be acceptable.

4. The bid documents have been revised to include updated language. Specifically, the bonding requirements have been added to the document.