

RFAI Addendum #1 RFP #21-03
Phase 5 Drainage Improvements

1. What is the specification on the sock pipe, is it dual wall or single wall?

The sock pipe should be dual wall N-12 pipe. The bid sheet has been revised to include a deduction amount for single wall sock pipe as an optional alternate.